



Town of North Yarmouth

Planning Board

FINDINGS OF FACT

September 13, 2022

Deacon Hayes Major Subdivision / Site Plan Review

Deacon Hayes Commons Site & Subdivision Plan

Site Plan Review - Findings of Fact:

1. Utilization of the Site

- The existing site is flat and the development is surrounded by residential homes, an auto shop, a preschool, North Yarmouth Town Hall, and Memorial Park.
- The proposed impervious area will be approximately 25,418 square feet.
- No wetlands, vernal pools, or significant wildlife habitat were identified within the project area.
- Toddy Brook stream is located east of the development and stream buffers are shown on the plan. See Sheet 1 Site & Demolition Plan dated February, 2022.
- Tree clearing on the site will be minimal and limited to those trees that line Parsonage Road.

2. Utilities

- The residential units will utilize underground electricity, cable communications, telephone and water supply.
- The 12" water main is shown on the Grading & Erosion Control Plan revised June 28, 2022 under Walnut Hill and Parsonage Road.
- The 1" domestic water lines will connect to each of the units.
- Each unit will connect to a septic sewer system. See Sheet 2 Grading & Erosion Control Plan dated February, 2022.
- The applicant has provided an updated groundwater impact analysis from Mark Cenci Geologic Inc. dated August 26, 2022. The single septic system exceeds 2,000 gallons per day and is regulated as an Engineered System by the Division of Environmental Health. The calculations provided shown that the wastewater plume does not exceed 5 mg/liter and is directed east.

3. Building Standards

- The applicant has submitted exterior building plans that comply with the building standards outlined in Section 10.4 of the Zoning Ordinance.



Town of North Yarmouth

Planning Board

FINDINGS OF FACT

September 13, 2022

Deacon Hayes Major Subdivision / Site Plan Review

4. Impact on Community Facilities

- No adverse impact on community facilities will result from the development.

5. Hazardous Materials and Emissions

- No hazardous materials and emissions will result from the development.

6. Exterior Lighting

- All residential units will include porch lights and entrance lights.
- The applicant is proposing full cutoff dark sky lighting for the units.

7. Financial and Technical Capacity

- The applicant has provided a letter of financial capacity from GenX Lending dated May 25, 2022.

8. Landscaping, Buffers and Screening

- An 8-foot-tall vinyl stockade fence is shown on the Site & Demolition plan revised June 28, 2022 along the northwestern property line to screen from abutting properties.
- One of the landscaped islands has been relocated to be further away from the disposal area shown on the updated Site & Demolition Plan.
- New trees and shrubs are shown on the site plan between the units and surrounding the parking area. The applicant has provided a list of trees and shrubs to be used on the amended site plan dated May 26, 2022.
- A 5 (five) foot wide grassed esplanade will be added between the sidewalk and Walnut Hill Road.

9. Noise

- The proposed development will not result in noise levels that will be objectionable to surrounding uses.

10. Signs

- No new signs will be included for the project.



Town of North Yarmouth

Planning Board

FINDINGS OF FACT

September 13, 2022

Deacon Hayes Major Subdivision / Site Plan Review

11. Storage of Materials

- The project will not include any exposed hazardous outdoor storage material.
- The project will not include any garbage disposal units (see Subsurface Wastewater Disposal System application dated March 9, 2022).

12. Stormwater Control

- Drainage flows southwest towards the manmade stormwater pond. See Sheet WS-1 Watershed Plan dated April 18, 2022.
- A 4-foot-wide drip edge has been provided around the homes to infiltrate stormwater runoff. See WS-1 Watershed Plan dated April 18, 2022.
- The applicant has provided both pre and post development stormwater calculations and the project is anticipated to mitigate peak flows to the stormwater pond.
- A new catch basin will be located over the existing 24" diameter culvert to capture the stormwater runoff from Walnut Hill Road. Details for the catch basin are shown on Sheet 3 Construction Drawings.
- The project will comply with DEP and Soil and Water Conservation District Best Management Practices for stormwater and erosion control.
- The project will add less than an acre of impervious area and therefore will not require a DEP permit under Chapter 500.

13. Protection of Significant Wildlife Habitat

- No significant wildlife habitat is located within the project area.

14. Access Management, Parking and Vehicular Circulation

- Access to the units will come from the paved driveway off Parsonage Road.
- The applicant has received a waiver from estimated peak hour traffic (Section 4.4f.13). Vehicular traffic to the site will be minimal.
- A turnaround space and "no parking" sign is marked on the site plan revised June 28, 2022 for emergency vehicle access.

15. Pedestrian Ways and Bicycle Access

- A new 5-foot-wide paved sidewalk will be added along Parsonage Road, Walnut Hill Road, and on the southern side of the parking lot.



Town of North Yarmouth

Planning Board

FINDINGS OF FACT

September 13, 2022

Deacon Hayes Major Subdivision / Site Plan Review

- The sidewalk located along Walnut Hill Road has been moved further away from the street for safety and construction purposes shown on the Subdivision Plan dated June 28, 2022.
- A 5-foot wide path is shown connecting from the parking area to the manmade pond.
- Each residential unit will have direct access to the public sidewalk and the sidewalk from the parking area.

16. Off-Street Parking and Loading

- The development includes a 29-space parking lot with ADA accessible parking spaces. See Sheet 1, Site & Demolition Plan and Sheet 4 Construction Details updated March, 2022.
- Parking is adequate to accommodate users during the week.
- The locations of snow removal areas are shown surrounding the easterly side of the parking area on the Site & Demolition Plan revised June 28, 2022.

Subdivision Review – Findings of Fact

1. General Layout: Lots, Blocks, Utilities, Monuments, and Back Lots

- Each of the buildings are on their own individual lots and meet all dimensional requirements from the Ordinance.
- Units 4, 8, and 11 will be reserved for affordable housing.
- Iron pipe monuments are shown at the corners of development boundaries on the Boundary Survey dated May 18, 2021.
- See #2 Site Plan Review for information about utilities.

2. Erosion and Sedimentation Control

- See #12 Site Plan Review for information about erosion and stormwater management.

3. Floodplain Management

- The development is not located in a 100-year floodplain.

4. Historic and Archaeological Sites

- The development does not contain historic or archaeological resources.



Town of North Yarmouth

Planning Board

FINDINGS OF FACT

September 13, 2022

Deacon Hayes Major Subdivision / Site Plan Review

5. Sewage and Solid Waste Disposal

- The applicant has submitted a Subsurface Wastewater Disposal System application in compliance with the State of Maine Subsurface Wastewater Disposal Rules.
- The applicant has provided an updated hydrogeologic assessment from Mark Cenci Geologic Inc. dated August 26, 2022. The original hydrogeologic assessment dated May 24, 2022 assumed groundwater flow direction towards the manmade pond from four wastewater disposal areas located 100 feet apart. The plan has since been revised to include a single combined wastewater disposal area to be used by all residential units (see Grading & Erosion Control Plan).

6. Soil Suitability

- The soils are adequate to support the development. See Subsurface Wastewater Disposal System application, "Soil Profile Description and Classification" dated March 9, 2022.

7. Recreation and Open Space Land Development

- The development will not include land for recreation or open space development.

8. Water Supply

- The development will utilize public water.
- The applicant has attached a letter from Yarmouth Water District dated June 29, 2022 regarding capacity to serve the project.

9. Water Quality

- The development will not diminish or adversely impact water quality with conditions added by the Planning Board.

10. Subdivision Street Connectivity

- See #14 Site Plan Review access management and vehicular circulation standards.



Town of North Yarmouth

Planning Board

FINDINGS OF FACT

September 13, 2022

Deacon Hayes Major Subdivision / Site Plan Review

Site Plan - Conclusions of Law:

1. The development **will** reflect the natural capabilities of the site to support development.
2. Utilities serving developments in the Village Center District and Village Residential District **will** be installed underground.
3. The proposed development, with conditions added by the Planning Board, **will not** result in a negative impact to the environment or to the community facilities or services.
4. The development **will not** contribute emission of dust, ash, smoke or other particular matter.
5. The proposed development **will** have adequate exterior lighting to provide for its safe use during nighttime hours.
6. The applicant **will** have the financial capacity to complete the project.
7. The landscape **will** be preserved in its natural state, insofar as practicable, by minimizing tree and soil removal, retaining existing vegetation where desirable, and keeping any grade changes in character with the general appearance of neighboring areas.
8. The development **will** control noise levels such that it **will not** create a nuisance for neighboring properties.
9. ~~The size, location, design, color, texture, lighting and materials of all exterior signs **will/will not** detract from the design of proposed buildings and structures. (N/A)~~
10. ~~Exposed non-residential storage areas, exposed machinery, and areas used for storage **will/will not** have sufficient setbacks and screening. (N/A)~~
11. Adequate provisions **will** be made for the collection and disposal of all storm water that runs off proposed roads, parking areas, roofs and other surfaces.
12. Developments **will** be designed to protect and conserve important wildlife habitat to the greatest extent feasible.
13. The layout of the site **will** provide for the safe movement of passenger, service, and emergency vehicles throughout the site.
14. The site plan **will** provide for a system of pedestrian ways within the development appropriate to the type and scale of development.
15. Parking areas **will** be constructed to protect the natural environment and visual character of the community, improve pedestrian safety and accessibility, and promote the quality of life in developed areas.



Town of North Yarmouth

Planning Board

FINDINGS OF FACT

September 13, 2022

Deacon Hayes Major Subdivision / Site Plan Review

Subdivision - Conclusions of Law:

1. The proposed subdivision, with conditions added by the Planning Board, **will not** result in undue water or air pollution.
2. The proposed subdivision **will** have sufficient water available for the reasonably foreseeable needs of the subdivision.
3. The proposed subdivision **will not** cause an unreasonable burden on an existing water supply.
4. The proposed subdivision **will not** cause unreasonable soil erosion or reduction in the capacity of the land to hold water.
5. The proposed subdivision **will not** cause unreasonable highway or public road congestion or unsafe conditions.
6. The proposed subdivision, with conditions added by the Planning Board, **will** provide for adequate solid and sewage waste disposal.
7. The proposed subdivision **will not** cause an unreasonable burden on the ability of a municipality to dispose of solid waste and sewage.
8. The proposed subdivision **will not** place unreasonable burden on the ability of the local governments to provide municipal or governmental services.
9. The proposed subdivision **will not** have an undue adverse effect on the scenic or natural beauty of the area.
10. The proposed subdivision **will** be in conformance with a duly adopted subdivision regulation or ordinance.
11. The subdivider **will** have adequate financial and technical capacity to meet the standards.
- ~~12. Whenever situated, in whole or in part, within 250 feet of any pond, lake, river or tidal waters, the proposed subdivision **will/will not** adversely affect the quality of such body of water. (N/A)~~
- ~~13. The 100 year flood boundary **is/is not** shown on the plan. (N/A)~~
- ~~14. All freshwater wetlands **have/have not** been identified on maps submitted as part of the application. (N/A)~~
- ~~15. All farmland within the proposed subdivision **has/has not** been identified on maps submitted as part of the application. (N/A)~~
- ~~16. Any rivers, streams, or brooks within or abutting the proposed subdivision **have/have not** been identified on maps submitted as part of the application. (N/A)~~
17. The proposed subdivision **will** provide for adequate storm water management.
- ~~18. Any lots in the proposed subdivision with frontage on a river, stream, brook, or great pond **have/do not have** a lot depth to shore frontage ratio greater than 5 to 1. (N/A)~~



Town of North Yarmouth

Planning Board

FINDINGS OF FACT

September 13, 2022

Deacon Hayes Major Subdivision / Site Plan Review

- 19. The long term cumulative effects of the proposed subdivision ~~will/will not~~ unreasonably increase the great pond's phosphorus concentration during the construction phase and life of the proposed subdivision. **(N/A)**
- 20. If the subdivision crosses municipal boundaries, the proposed subdivision ~~will/will not~~ cause unreasonable traffic congestion or unsafe conditions with respect to the use of existing public ways in an adjoining municipality. **(N/A)**
- 21. Timber on the parcel ~~has/has not~~ been harvested in violation of liquidation harvesting statutes and rules. **(N/A)**

Conditions of Approval

- 1. Prior to the issuance of a certificate of occupancy, the landowner or responsible homeowners association shall provide to the Code Enforcement Office an Operations & Maintenance Plan approved by the State of Maine.
- 2. Landowner or responsible homeowners association shall comply with the Operations and Maintenance plan.
- 3. Landowner or responsible homeowners association shall submit to the Code Enforcement Office a maintenance agreement with Fuji Clean and comply with that maintenance agreement.
- 4. Performance guarantee – Prior to the issuance of building permits, the applicant will submit an Irrevocable Letter of Credit in the amount of \$100,000 to be approved by Selectboard.
- 5. Consistent with Sec. 5.8(C) of the Land Use Ordinance, the units shall be built in two phases to prevent classroom overcrowding, so that the building permits for the second half of the units shall not be issued until the calendar year following the building permits that have been issued for the first six units, also subject to the Town's current building cap ordinance.

Planning Board Members

Jeffrey Brown

Kimry Corrette

Sanford Peabody

~~Paul Metevier~~

Chris Cabot